



MICHELLE LUJAN GRISHAM
GOVERNOR

JAMES C. KENNEY
CABINET SECRETARY

Notification Sent Via Email

8/12/2022

Berna Georgescu
South Hills Water Company
5605 Don Lorenzo Dr. SW
Albuquerque, NM87121

RE: Level 1 Assessment – Treatment Technique Trigger
WSS# NM3510201

Dear Berna Georgescu:

On 8/11/2022 the South Hills Water Company water system triggered a Level 1 Assessment under the Revised Total Coliform Rule (RTCR). This assessment was triggered because two or more of your microbiological samples collected during the month of August were positive for Total Coliform.

Pursuant to Section 20.7.10.100 New Mexico Administrative Code (NMAC) [incorporating 40 Code of Federal Regulations (CFR) Section 141.859(a)(1)] you are required to conduct a Level 1 Assessment and report the assessment findings and any corrective actions to the New Mexico Environment Department's Drinking Water Bureau (NMED-DWB) within 30 days of the assessment trigger date. A Level 1 Assessment may only be conducted by a SWA, WS3, WS4 certified operator or any level of operator that attended an NMED approved 8 Hour RTCR training session. A Level 1 Assessment Report can be downloaded from the NMED-DWB website at https://www.env.nm.gov/drinking_water/rtcr/

Failure to conduct and report an RTCR Level 1 Assessment or corrective actions as defined in the New Mexico Drinking Water Regulations, 20.7.10.100 NMAC [incorporating 40 CFR Section 141.859(a)(1)] will result in a notice of violation assessed to the South Hills Water Company.

If you have any questions or need assistance, please call 505-629-3085 or e-mail chet.markham2@state.nm.us.

Respectfully,

A handwritten signature in blue ink, appearing to read "Chet Markham".

Chet Markham, RTCR Rule Administrator
Drinking Water Bureau
Water Protection Division

Enclosures: RTCR Assessment Guidance

cc: Area Supervisor Brandi Littleton (electronic)
South Hills Water Company water system Area Office file
Electronic Central File

SCIENCE | INNOVATION | COLLABORATION | COMPLIANCE